



INVOICE
 1162838
INVOICE DATE
 09/13/2024



SOLD TO: Enclave At Naples
 1295 Wildwood Lakes Blvd.
 19 Buildings
 Naples, FL 34104

SHIP TO: Enclave At Naples
 1295 Wildwood Lakes Blvd.
 19 Buildings
 Naples, FL 34104

CALL NO.	CUSTOMER NO.	P.O. NUMBER	TERMS	BRANCH
755675	EAN001		NET 30	4683 Laredo Ave Fort Myers, FL 33905-4924

COMMENTS

Caller Name: Joan Colosimo (239) 354 3200
 Call Details: This quote includes labor and material to repair the deficiencies found during the latest fire sprinkler inspection.

The following was reported at: Enclave at Naples
 <Tech will need to drain the sprinkler system on each building before sprinkler heads can be replaced.>

***1160 Wildwood Lakes Blvd ***

- 1. Unit 201 painted pendant in AC closet. Material and Labor - \$135.85
- 2. Unit 304 painted pendant above laundry. Material and Labor - \$135.85

***1170 Wildwood Lakes Blvd ***

- 1. Unit 105 painted sidewall outside laundry. Material and Labor - \$135.85

***1180 Wildwood Lakes Blvd ***

- 1. Unit 304- 1 painted pendent in laundry and 1 painted sidewall in master bathroom entry. Material and Labor - \$271.70

***1185 Wildwood Lakes Blvd ***

- 1. Unit 304- Painted pendent in master bedroom. Material and Labor - \$135.85

***1190 Wildwood Lakes Blvd ***

- 1. Unit 305 painted pendant in AC closet. Material and Labor - \$135.85

***1195 Wildwood Lakes Blvd ***

- 1. Unit 203 painted sidewall in master bedroom. Material and Labor - \$135.85
- 2. Unit 104 has 2 heads that need extended in entry way. Material and Labor - \$301.80

***1210 Wildwood Lakes Blvd *** (8 foot ladder required)

- 1. Unit 208- Painted pendent in hall of laundry. Material and Labor - \$135.85
- 2. Unit 304-Livingroom head obstructed with tape. Tech will remove the tape on the sprinkler head. Material and Labor - \$65
- 3. Unit 104- Painted pendent in front of entry door. Material and Labor - \$135.85

***1220 Wildwood Lakes Blvd ***

- 1. Unit 202- Laundry room was covered, remaining cover around trim will not come off. Tech will replace the trim ring. Material and Labor - \$67.96
- 2. Unit 305 covered head in laundry. Material and Labor - \$135.85

***1230 Wildwood Lakes Blvd ***

- 1. Unit 106 has 2 sidewalls painted in master bedroom and 1 sidewall painted in living room. Material and Labor - \$407.55

***1235 Wildwood Lakes Blvd *** (6 to 8 foot ladder needed)

- 1. Unit 201- 2 pendants in living room painted/covered and 2 pendants in master bedroom painted, 1 pendant in kids bedroom. Material and Labor - \$679.25

***1240 Wildwood Lakes Blvd ***

- 1. Unit 201 pendant painted in AC closet. Material and Labor - \$135.85

***1250 Wildwood Lakes Blvd ***

- 1. Unit 304- 1 Painted pendent in master bedroom. Material and Labor - \$135.85

Alabama A-0457 Florida EF20001320 Georgia LVA205941 North Carolina 29611-SP-FA/LV South Carolina FAC.3385 M

- 2. Unit 204- 1 painted sidewall in hall of laundry. Material and Labor - \$135.85
- 3. Unit 207- 1 Missing trim in kitchen. Tech will replace the missing trim ring. Material and Labor - \$67.96
- 4. Unit 107- 1 Painted sidewall in spare bedroom, and 1 painted pendant in hallway. Material and Labor - \$271.70

***1260 Wildwood Lakes Blvd ***

- 1. Unit 201 painted pendent in all outside AC. Material and Labor - \$135.85

***1265 Wildwood Lakes Blvd ***

- 1. Unit 208 painted sidewall in laundry. Material and Labor - \$135.85

***1275 Wildwood Lakes Blvd ***

- 1. Unit 205 AC closet missing trim. Tech will replace the missing trim ring. Material and Labor - \$67.96

-- THIS QUOTE ASSUMES REASONABLE AND TIMELY ACCESS TO UNITS ON CONSECUTIVE DAYS. SITE MAINTENANCE IS TO ACCOMPANY WAFS SERVICE TECHNICIAN IN UNITS.

*NOTE: The above items are priced assuming all work will be contracted for and completed on consecutive days. WAFS reserves the option to revise pricing if all the above scope is not contracted for.

-- If broken CPVC pipe occurs there is a 24-hour cure period after last glue joint is made. WAFS will not supply fire watch during cure period. A separate quote will be sent if WAFS is to supply fire watch. Broken CPVC pipe repairs will be an additional \$185.00 per break while we are on site, this will be billed in additional to original contract pricing.

Solution: 08/19/2024 (LAGUTIERREZ)

- @ 1160 Wildwood Lakes Blvd.
- > Units 201 & 304: Replaced sprinkler heads.
- @ 1170 Wildwood Lakes Blvd.
- > Unit 105: Replaced sprinkler head.
- @ 1180 Wildwood Lakes Blvd.
- > Unit 304: Replaced sprinkler heads.
- @ 1185 Wildwood Lakes Blvd.
- > Unit 304: Replaced sprinkler head.
- @ 1190 Wildwood Lakes Blvd.
- > Unit 305: Replaced sprinkler head.
- @ 1210 Wildwood Lakes Blvd.
- > Units 208, 304 & 104: Replaced sprinkler heads.
- @ 1220 Wildwood Lakes Blvd.
- > Units 202 & 305: Replaced sprinkler heads & trim ring.
- @ 1195 Wildwood Lakes Blvd.
- > Units 203 & 104: Broken pipe, we capped 3/4 lines. Joan says they'll do their own fire watch.

08/20/2024 (LAGUTIERREZ)

- @ 1195 Wildwood Lakes Blvd.
- > Unit 104: Replaced broken sprinkler head.
- @ 1230 Wildwood Lakes Blvd.
- > Unit 106: Replaced sprinkler heads.
- @ 1235 Wildwood Lakes Blvd.
- > Unit 201: Replaced sprinkler heads.
- @ 1240 Wildwood Lakes Blvd.
- > Unit 201: Replaced sprinkler head.
- @ 1250 Wildwood Lakes Blvd.
- > Units 304, 204, 207 & 107: Replaced sprinkler heads & trim ring.
- @ 1260 Wildwood Lakes Blvd.
- > Unit 201: Replaced sprinkler head.
- @ 1265 Wildwood Lakes Blvd.
- > Unit 208: Replaced sprinkler head.
- @ 1275 Wildwood Lakes Blvd.
- > Unit 205: Replaced trim ring.

08/21/2024 (LAGUTIERREZ) Returned system back to normal.

DESCRIPTION	PRICE (BEFORE TAXES IF APPLICABLE)
Material, Labor and Other:	\$4,287.78

Please reference invoice number on payment. Thank You!

ACH: Routing #063104668; Acct #0330089824; email: accrec@waynefire.com

Credit card: a surcharge of 3% will be applied to purchases.

Questions Regarding this invoice please contact:

Name: Courtney A LaBar

Phone: (239) 433 3030

Email: calabar@waynefire.com

SUBTOTAL:	\$4,287.78
SALES TAX:	\$0.00
TOTAL:	\$4,287.78

Remit To:

Dept # 9942

Wayne Automatic Fire Sprinklers Inc

PO Box 850001

Orlando, FL 32885-9942

Phone: (407)656-3030

Fax: (407)656-8026